

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-0078:195 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: ADEMCO, 165 Eileen Way, Syosset, NY 11791
Contact: Dave Kalmus (516) 921-6704

DESIGN: Models 472491 and 472491D* AC Communicator Modules. This unit is designed to transmit reports to the central station when it is directly wired to the telephone line. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 12 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product designation and UL label.

APPROVAL: Listed as control unit accessory for use with listee's separately listed compatible fire alarm control units.

*Rev. 06-06-01



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 8, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager